



CERTIFICATE: VERIFIED TECHNOLOGY FOR HYGIENE IN AHUs

according to **DIN 1946-4** (9/2018)

Ventilation and air conditioning –
Part 4: Ventilation in buildings and rooms of health care

on behalf of: **PRO-KLIMA** d.o.o.
Gradna 78e
HR-10430 Samobor

brand / type: PROKLIMA / KG Flex

This standard applies to the planning, construction and qualification of ventilation and air conditioning systems in buildings and rooms used in the health sector, particularly those used for medical examinations, treatments and operations on humans, including any rooms directly connected to such rooms via doors, corridors/hallways, etc.

AHUs has to be built in accordance to

DIN EN 1886 "Ventilation for buildings - Air handling units: Mechanical performance",
as well as the

DIN EN 13053 "Ventilation for buildings - Air handling units: Rating and performance
for units, components and sections".

**The manufacturer meets the requirements
to reach the conformity with the DIN 1946-4**

