



Product Service

EC-Attestation of Conformity

No. M8 08 04 62479 002

Holder of Certificate: PROKLIMA d.o.o.

Talani 14
10000 Zagreb
CROATIA

Product: Air conditioning equipment

Model(s): Air handling unit
KU 3-LU25S
KU 9/8-DU25S

Parameters:

KU 3-LU25S	
Rated Voltage	3x400V 50 Hz
Rated Input Power	1,1 KW 2,7 A
Degree of protection	IP 54
Weight	259 kg
KU 9/8-DU25S	
Rated Voltage	3x400V 50 Hz
Rated Input Power	7,5 KW 15 A
Degree of protection	IP 54
Weight	1490 kg

Tested according to: EN 60204-1:1997
EN 12100-1/-2:2003

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

Test report no.: 71318317 Rev.2



Date, 2008-04-07

CE After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.